



TCE VI Case Study

Site Overview

- 30 acre research facility
- Located adjacent to the Connecticut River
- TCE use 1960-1987
 - Storage: UST and AST – Documented spills/leaks
 - Use: secondary refrigerant
- Depth to GW 100 to 120 ft
- Primary source of VI: significant high strength vadose zone source



TCE VI Case Study

Short term study to compare TO-15 to portable Hapsite GC/MS

- 24 day study
 - First 5 days generally low pressure atmospheric conditions
 - Remainder of study associated with high pressure
- Collected 8 hour Summa canister samples for TO-15 analysis
- Collected 8-hour Bottle-Vac samples for Hapsite analysis
- Study indicates Hapsite results are bias high compared to TO-15 at low concentrations



	TC	E
VI	Case	Study

HealthMate[™] 450 Portable Indoor Air Treatment Unit

Assessment

Range of TCE levels prior to assessment*	TCE Baseline 8-hour	TCE after 12 Hours of filtration 8-hour	% Reductions
13 - 210	16	9.1	46%
18 - 61	27	3.6	87%
2.2 - 9.1	2.4	1.4	42%

Concentrations are in µg/m3

*Elevated levels were associated with tropical depression Irene







11

TCE VI Case Study

Hapsite portable GC/MS Rapid assessment Disadvantages

- Expensive to purchase and operate
- Can be frustrating
 - Chasing transient background sources
- Can have down time
- Bias high at low levels near action level
 - Can lead to over representing risk





T VI Cas	CE e Study	
y Care SSDS	Effectivenes	SS
Maximum TCE Concentration	Maximum TCE Concentration	
before Mitigation	after Mitigation	% Reductions
before Mitigation 11,000	after Mitigation 1.7	% Reductions
before Mitigation 11,000 140	after Mitigation 1.7 0.27	% Reductions >99.9% >99.9%
	T VI Cas y Care SSDS Maximum TCE Concentration	TCE VI Case Study y Care SSDS Effectivenes Maximum Maximum TCE TCE Concentration Concentration

TCE VI Case Study Summary

Main Laboratory Building

- Rapid assessment using on-site portable GC/MS
 - EPC's (2-3 week rolling average)
 - Sleuthing
- Indoor air treatment
 - Over 250 indoor air purification units deployed
- Sub-slab depressurization system installed

Day Care

- Sub-slab depressurization system
 - 99.9% reductions

TCE VI Case Study Summary

Continuing Efforts in Main Lab

- Address additional sources/routes of entry
 - Historic TCE refrigerant piping
 - Foundation drains
 - Roof drains
 - Foundation walls
 - Ambient air
- Assess continued use of air purification units
- Demonstrate SSDS effectiveness





